

إدارة مختبر دبي المركزي
Dubai Central Laboratory Department (DCLD)

شهادة مطابقة للمنتج CERTIFICATE OF PRODUCT CONFORMITY

Certificate number:	CL21020763	رقم الشهادة:
Issued to the Product:	Aluminum Composite Panel Details as per the attached Scope of Certification	تم منح الشهادة للمنتج:
Manufactured by:	ALUCOPANEL MIDDLE EAST LLC	مصنع من قبل:
Address:	National Industries Park, Dubai, UAE	العنوان:

تم تقييم المنتج وفقاً لمرجع إدارة مختبر دبي المركزي رقم (IC) DM-DCLD-RD-DP21-2001 "الأحكام العامة لنظام بلدية دبي لمنح شهادة مطابقة المنتج من قبل طرف ثالث من خلال تقييم المصنع" والأحكام الخاصة ذات الصلة، وتم الإقرار بناءً عليه بأنه مطابق للمواصفة القياسية:

The product has been assessed in accordance to DCLD Document Reference No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

DMS 036: 2021

وطبقاً لذلك، تفوض إدارة مختبر دبي المركزي الشركة المصنعة المذكورة أعلاه بوضع علامة المطابقة للمنتج على المنتج/المنتجات المذكورة أعلاه

Accordingly, DCLD hereby authorizes the above manufacturer to affix the DCL Product Conformity Mark on the above-mentioned product(s)

Original Issue Date:	07 February 2021	تاريخ الإصدار الأولي:
Current Issue Date:	07 February 2024	تاريخ الإصدار الحالي:
Valid until:	06 February 2025	صالحة لغاية:



ARIF AL MARZOOQI

for Certification and Quality Control of Products Section Manager
Dubai Central Laboratory Department-Dubai Municipality



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.

This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

OPEN-DATA

DM-DCLD-F-IC-2031 Rev 23

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL21020763**

Certificate Issued To:	ALUCOPANEL MIDDLE EAST LLC National Industries Park, Dubai, UAE
Applicable Standard Specification:	DMS 036: 2021 - "Standard Specification for Aluminum Composite Panel"
Applicable Specific Rules:	DM-DCLD-RD-DP21-2214 (IC) - Specific Rules for Certification of Aluminum Composite Panel through Factory Assessment.

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
1.	Aluminum Composite Panel	Alucopanel® FR	Panel Thickness: 4mm Panel Weight: ≥ 8.64 kg/m ² Standard Width: 1000, 1250, 1500 mm Length: up to 6000 mm Skin Thickness: 0.5 mm Reaction to Fire: Class B, s1, d0 as per EN 13501-1
2.	Aluminum Composite Panel	Alucopanel® FR	Panel Thickness: 6mm Panel Weight: ≥ 12 kg/m ² Standard Width: 1000, 1250, 1500 mm Length: up to 6000 mm Skin Thickness: 0.5 mm Reaction to Fire: Class B, s1, d0 as per EN 13501-1
3.	Aluminum Composite Panel	Alucopanel® A2	Panel Thickness: 4mm Panel Weight: $\geq 8 \pm 0.5$ kg/m ² Standard Width: 1000, 1250, 1500 mm Length: up to 6000 mm Skin Thickness: 0.5 mm Reaction to Fire: Class A2, s1, d0 as per EN 13501-1
4.	Aluminum Composite Panel	Alucopanel® A2	Panel Thickness: 6mm Panel Weight: $\geq 11.8 \pm 0.5$ kg/m ² Standard Width: 1000, 1250, 1500 mm Length: up to 6000 mm Skin Thickness: 0.5 mm

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL21020763**

			Reaction to Fire: Class A2, s1, d0 as per EN 13501-1
5.	Aluminum Composite Panel	Alucopanel [®] A1	Panel Thickness: 4mm Panel Weight: $\geq 7.8 \pm 0.5$ kg/m ² Standard Width: 1000, 1250, 1500 mm Length: up to 6000 mm Skin Thickness: 0.5 mm Reaction to Fire: Class A1, as per EN 13501-1

Note 1: This document forms an integral part of the Certificate of Product Conformity bearing the same Certificate Number.

Note 2: The above product shall bear the DCLD Conformity Mark (applied on each product or on the packaging).

Note 3: Product Performance meets Tables 2 & 3 of DMS-036 requirements.

Note 4: The certificate shall only be for the product "as panels" and shall not cover the "cladding" systems made from these panels.

Note 5: As applicable, other properties in the product standard specification which were excluded in the specific rules as approved by the certification body authorized personnel are to be verified by the end-user of the product (if needed).

Original Issue Date: 07 February 2021

Current Issue Date: 07 February 2024

Valid Until: 06 February 2025



for **MANAGER**

CERTIFICATION AND QUALITY CONTROL OF PRODUCTS SECTION